

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Nancy

results of lead in water test

Analysis Report

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

ORELAP 100016
EPA OR00028

Lab Order: 1609A13
NRC Sample ID: 1609A13-01A
Collection Date: 9/20/2016 9:09:00 AM
Received Date: 9/22/2016 10:00:00 AM
Reported Date: 9/29/2016 9:30:21 AM

Sample Information:

X023800 Ashwood School

Client Sample ID: Bottle #19770
Collectors Name:
Sample Location: Kitchen
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
	EPA 200.8	A	15.4	CF	0.1	ppb	20 AL	9/27/2016	OML

minimum Reporting level

Lead 15.4

EPA Limit = 20, no action required

but we must make report avail to public - I'll talk w/ melanie about putting on website and ~~cont.~~ notify parents - You or I can report to Board

Mary