

Water Testing Results - Ashwood School District

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Pumphouse		8/13/2020	ND
Frost Free Fixture in Lawn		8/13/2020	17
Kitchen Sink		11/6/2020	22.4
Classroom 2 Sink		11/6/2020	5.67
Boy's Restroom Sink		11/6/2020	13.3
Girl's Restroom Sink		11/6/2020	1.1
RETEST (After replacing fixtures and shut-offs)			
Kitchen Sink		5/20/2021	6.8
Girl's Restroom Sink		5/20/2021	ND

ND = Non Detect - Lead level is below the set detection limits of 1 ppb